



Product Service

CERTIFICATE

Z2 076729 0107 Rev. 01

Model(s):

SRP-xxx-6MA (xxx=330-375, in step of 5);
SRP-xxx-6MB (xxx=275-310, in step of 5);
SRP-xxx-6MA-HV (xxx=330-375, in step of 5);
SRP-xxx-6MB-HV (xxx=275-310, in step of 5);
SRP-xxx-E01A (xxx=365-410, in step of 5);
SRP-xxx-E01B (xxx=305-340, in step of 5);
SRP-xxx-E01A-HV (xxx=365-410, in step of 5);
SRP-xxx-E01B-HV (xxx=305-340, in step of 5);
SRP-xxx-BMA (xxx=330-380, in step of 5);
SRP-xxx-BMB (xxx=275-315, in step of 5);
SRP-xxx-BMC (xxx=305-345, in step of 5);
SRP-xxx-BMA-HV (xxx=330-380, in step of 5);
SRP-xxx-BMB-HV (xxx=275-315, in step of 5);
SRP-xxx-BMC-HV (xxx=305-345, in step of 5);
xxx is standing for rated output power at STC.

Parameters:

Safety Class: Class II
Max. System Voltage: 1000V DC or 1500 V DC
Construction: Framed, with Junction box,
cable and connector.
Fire Safety Class: Class C according to UL790
PID Test Condition: -1500V and -1000V, 288 h,
85 % RH, 85°C according to
IEC TS 62804-1 stress method a).

Tested according to:

IEC 61215-1(ed.1)
IEC 61215-1-1(ed.1)
IEC 61215-2(ed.1)
IEC 61730-1(ed.2)
IEC 61730-2(ed.2)
PPP 58042B:2015

Production Facility(ies):

076729, 004571, 095290, 098633