

## CERTIFICATE

No. Z2 076729 0101 Rev. 02

**Holder of Certificate:** Seraphim Solar System Co.,Ltd.

No.1-2, Hengyao Rd, Henglin Zhen

Wuiin District 213101 Changzhou

PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:** 



**Product:** Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

Mono-crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704061801207-03

Valid until: 2023-10-31

Date, 2018-11-02 (Zhulin Zhang)

## CERTIFICATE

No. Z2 076729 0101 Rev. 02

Model(s): SRP-xxx-6MA (xxx=330-375, in step of 5);

SRP-xxx-6MB (xxx=275-310, in step of 5); SRP-xxx-6MA-HV (xxx=330-375, in step of 5);

SRP-xxx-6MB-HV (xxx=275-310, in step of 5);

SRP-xxx-E01A (xxx=365-410, in step of 5):

SRP-xxx-E01B (xxx=305-340, in step of 5);

SRP-xxx-E01A-HV (xxx=365-410, in step of 5);

SRP-xxx-E01B-HV (xxx=305-340, in step of 5);

SRP-xxx-BMA (xxx=330-380, in step of 5);

SRP-xxx-BMB (xxx=275-315, in step of 5);

SRP-xxx-BMC (xxx=305-345, in step of 5);

SRP-xxx-BMA-HV (xxx=330-380, in step of 5);

SRP-xxx-BMB-HV (xxx=275-315, in step of 5);

SRP-xxx-BMC-HV (xxx=305-345, in step of 5);

xxx is standing for rated output power at STC.

Parameters:

Safety Class:

Class II

Max. System Voltage:

1000V DC or 1500V DC Yangzhou Opto-Electrical

Test Laboratory:

Product Testing Institute

No.10 West Kaifa Road, Yangzhou,

225009 Jiangsu P.R.China

Construction:

Framed, with Junction box,

cable and connector.

Fire Safety Class:

Class C according to UL790

**Tested** 

according to:

IEC 61215-1(ed.1) IEC 61215-1-1(ed.1)

IEC 61215-2(ed.1) IEC 61730-1(ed.2)

IEC 61730-2(ed.2)

Production Facility(ies):

004571, 076729, 095290, 098633

Paris de la companya della companya